



MANUFACTURER'S DATA REPORT FOR INDIRECT FIRED HEATER COILS

(A) No. 498537

Manufactured by Bromley Mechanical Services (1985) Ltd., PO Box 404, 925 - 23 Street SW, Medicine Hat, AB, T1A 8R1

Manufactured for Encana Corporation, 3900, 421 - 7 Avenue SW, Calgary, AB, T2P 4K9

Ultimate Owner Same as Above

Location of Installation "C" Station

Mfg. Serial No. 316709 Code: ASME B31.3, Edition 1999 Addenda 2001

Drawing Number 30832 Rev.1 Year Built 2003 Intended Service Natural Gas/Oil/Water

a. Material Specifications SA106B SA105N 600 ANSI
Coil Ends (Flanges/N.P.T.) Rating

b. Material Specifications Coil Ends (Flanges/N.P.T.) Rating

a. Diameter 3" nps Nom. Thickness 0.300" O/A Length 145 ft C.A. 0.125"

b. Diameter Nom. Thickness O/A Length C.A.

a. Maximum Working Pressure 9308 kPa at Maximum Temperature 93 °C

b. Maximum Working Pressure kPa at Maximum Temperature °C

a. Hydrostatic Test Pressure 13962 kPa C.R.N. H5424.2

b. Hydrostatic Test Pressure kPa C.R.N.

Heating Surface 135 sq ft Radiography 100% (Random, % or Full)

Volume 7.20 cu ft or 0.20 cu m P.W.H.T. Nil

Remarks BWO 30832

CERTIFICATE OF COMPLIANCE

We certify that the statements in this report are correct and that all details of design, material, construction, and workmanship of this coil bundle are in accordance with Registered Design No.

Date July 21, 2003 Signed [Signature] For Bromley Mechanical Services (1985) Ltd. (Representative) (Manufacturer)

CERTIFICATE OF SHOP INSPECTION

I, the undersigned, a duly authorized Safety Codes Officer employed by The Alberta Boilers Safety Association have inspected the above Heater Coils and state that, to the best of my knowledge and belief, the construction is in accordance with the Alberta Safety Codes Act and Regulations.

Date July 21/03 Signed [Signature]